

January 2022 Operations Report

Water

- **Flow: Well 1b-** 1,625,600 gallons **Well 2-** 104,900 gallons **Total-** 1,730,500 gallons **Daily Avg-** 55,822 gallons
- **Water Leaks/Shutoffs:** During the month operators had three shutoff requests due to water leak at residences; #24 N Pinion, #1 Ponderosa, & #8 Cedar. These leaks contributed to the higher daily average and Well 2 running more than usual. During the winter months, Well 2 is only run weekly for a short duration for an operational check.

Wastewater

- **Flow:** WWTP 6- 251,269 gallons WWTP 7- 1,641,220 gallons Total- 1,892,489 gallons Daily Avg- 61,048 gallons

Misc., Future & Small Projects

- **Tree Removal:** The District had two trees in the greenbelt area on Cottonwood, across the street from the building removed. Residents adjacent to the area were concerned about these trees falling and damaging homes. The trees were leaning extremely towards the adjacent homes, creating a liability for the district should the trees end up falling.
- **Auto CAD Map Update:** Operators use an Auto CAD map to identify locations of water boxes of residents and locations of other infrastructure. This map is missing newer development "The Village" on Eureka Springs. Operators have contacted Joy Engineering, who did the installation, requesting As-Built maps of the area. Currently, the district does not have As-builts maps of the area. Should Joy Engineering have the maps, the Auto-CAD map will be updated and the district will have a set of As-Built maps.