

# September 2022 Operations Report

## Water

- **Flow- Well 1b:** 6,539,800 gallons **Well2:** 2,725,900 gallons; 29% of total monthly flow **Total:** 9,265,700 gallons **Daily Average:** 298,894 gallons. **September 2021:** 10,361,340 gallons. There was a nine day stretch where Well 2 did not run.
- **No leaks reported during September.**
- **Backflow Preventer Testing:** Sierra Backflow tested seven devices on 9/28. These backflow devices are required to be tested annually. None of the devices failed. Records of the testing are reviewed by the State when they do a water system inspection

## Wastewater

- **Flow- WWTP 6:** 214,778 gallons; Avg Gal/day 6,928 gallons **WWTP 7:** 703,151 gallons Avg Gal/day 23,438 gallons **Total:** 917,929 gallons

## Misc. & Small Projects

- **Ponderosa Tree Removal:** The trees behind 56 Ponderosa were finally removed. Amos Enterprises was able to remove the trees within a couple weeks of being contacted.
- **Slash Piles:** Operators borrowed Unit 6's dump trailer and used the Bobcat to load and haul the slash piles on CSD property to the Graeagle burn pile.