

December 2022 Operations Report

Water

- **Flow- Well 1b:** 1,572,000 gallons **Well2:** 800 gallons **Total:** 1,572,800 gallons **Daily Average:** 50,735 gallons.
- **Shutoffs & Leaks:** During the freezing weather the operators had four requests for shutoffs. 137 Cottonwood requested shutoff for the winter season, 65 Eureka Springs requested their service to be turned on upon arrival for holidays. 49 Oak Court & 180 Tamarack Place were requests for shutoff due to leaks.
- **Water System Inspection:** December 19th, our regulator from the Sate Water Board did an inspection of our water system. We snowshoed up to the water tanks and made visits to both Well 1b and Well 2. There were no immediate issues that needed to be addressed following the inspection. The District should receive an official within a few months.

Wastewater

- **Flow- WWTP 6:** 217,434 gallons ; Avg Gal/day 7,014 gallons **WWTP 7:** 1,380,748 gallons Avg Gal/day 44,540 gallons **Total:** 1,598,182 gallons
- **WWTP 7 Lift Station Pump Replacement:** Pump #2 at the lift station on Sequoia failed during the early part of December. Operators had Plumas Sanitation pump out one truck load from the basin to help maintain the level overnight. The next day, operators replaced the pump with a rebuilt pump from a previous situation that was similar. Plumas Sanitation was onsite to maintain basin level while the pump replacement took place. The pump was successfully replaced and taken to Sparks Electric Motor for repair.

Misc. & Small Projects

- **Snow Removal:** The series of recent storms has kept operational staff busy removing snow from District roads, office parking lot, treatment facilities, and the mailbox.