

Report on Arsenic Compliance Actions

June 16, 2021

Submitted by John Rowden, Interim General Manager

Arsenic Compliance Level.

The most recent reported sample result from the Compliance point was taken on June 3, 2021 showed the arsenic levels at 10 ppb. The second quarter average was 9 ppb. The current Running Annual Average (RAA) is 10 ppb.

The June 3 reportable result from Well 1B was 7 ppb; The second Quarter 2021 average was 7 ppb, the RAA is 8 ppb.

The June 3 reportable result from Well 2 was 20; The second Quarter 2021 average was 16 ppb, the RAA is 15 ppb.

Iron and Manganese Compliance Levels

The most recent results of the tests of the Quarterly samples taken on April 4, 2021 for Iron were .660 mg/l at Well 1B and .470 mg/l at Well 2; for Manganese were .100 mg/l at Well 1B and .073 mg/l at Well 2. (The Secondary Standard for Iron is .300 mg/l. The Secondary Standard for Manganese is .05 mg/l.).

Remediation Project Development

The District will be applying for a construction loan from the State Revolving Fund. A Task Order for The District Engineer, Farr West Engineering, to help with acquiring the funds was approved at the May meeting. Also, the Board approved a contract with Hauge Brueck Associates to complete a cultural and biological study and report required by the loan application process. The site visit by the consultant is scheduled for June 12.