

July 2021 Operations Report

Water

- **Flow: Well 1b-** 7,451,300 gallons **Well 2-** 5,356,600 Gallons **Total -** 12,807,900 gallons
Daily Avg: 413,158 gallons

Well 1b had a flow of a million less gallons for the month of July compared to June; this due to the well shutting off when it reaches the preset low level. The well normally operates in this mode during this time of the year. Well 2 had a flow of a million more for the month of July compared to June. Overall total was a million gallons more than June.

- **Water Conservation:** There are still some residents that have been in violation of Stage 2 guidelines. Compared to July 2020, this district has saved 1,490,000 gallons; with a daily average of 413,000 gallons, compared to 461,000 gallons daily in 2021.
- **Cottonwood Valve Box:** Operators replaced the broken valve box on Cottonwood near the mailbox cluster. An encroachment permit was granted by the county; asphalt was cut, removed, box replaced, and asphalt patched.

Wastewater

- **Flow: WWTP # 6-** 401,771 gallons **WWTP # 7-** 840,733 gallons **Total-** 1,242,504 Gallons
- **WWTP 6 Painting:** Operators painted the building for the treatment plant. Colors for the plant match the condos in the area. The project took about a week to complete with prep work and painting.

Misc., & Small Projects

- **Debris Removal:** Operators have continued to cut and remove trees and other debris from district properties.