

Report on Arsenic Compliance Actions

January 13, 2021

Submitted by John Rowden, Interim General Manager

Arsenic Compliance Level.

The most recent reported sample result from the Compliance point were taken on December 3, 2020 showed the arsenic levels at 7 ppb. The fourth quarter average was 9. The current Running Annual Average (RAA) is 9 ppb.

The December 3, 2020 reportable result from Well 1B was 10 ppb; The 4th Quarter 2020 average was 8 ppb, the RAA is 8 ppb.

The December 3, 2020 reportable result from Well 2 was 12; The 4th Quarter 2020 average was 14 ppb, the RAA is 13 ppb.

Iron and Manganese Compliance Levels

The most recent results of the tests of the Quarterly samples taken on October 6, 2020 for Iron were .280 mg/l at Well 1B and .450 mg/l at Well 2; for Manganese were .092 mg/l at Well 1B and .101 mg/l at Well 2. (The Secondary Standard for Iron is .300 mg/l. The Secondary Standard for Manganese is .05 mg/l.)

Remediation Project Development

The Board will be considering the decision about constructing the Water Treatment Plant at its Regular Meeting on January 13, 2021.