

# Report on Arsenic Compliance Actions

September 13, 2017

Submitted by John Rowden, Interim General Manager

## **Arsenic Compliance Level.**

The last reported sample at the compliance point was on August 3, 2017 and showed that the arsenic level at the compliance point was 11 ppb. The EPA standard is 10 ppb.

Samples taken on August 3, 2017 showed the level at Well 1B at 7 ppb and the level at Well 2 at 15 ppb.

## **Remediation Project Development**

State Revolving Fund Loan. The Interim General Manager signed the loan package on August 8 and sent the signed pages back to the State for final approval. Approval was delayed due to a miscommunication with the District's legal counsel. The approving signatures need to be followed by an opinion letter from the District Counsel supporting the approval of the loan. The Opinion letter was not sent until August 28. The loan amount is \$350,000. The term of the loan is five years, but can be rolled into a longer term construction loan from the SRF.

Facility Location. The Board selected 208 Lundy Lane for the location of the Water Treatment Plant pending the demonstration that there was enough room on the parcel to accommodate the facility. Farr West Engineering surveyed the property however the completion of the survey was delayed by technical problems and the report will not be ready for the Board meeting.

Design Engineering. Upon final approval of the site, the Board will be asked to approve contracting for the design of the facility.