

Report on Arsenic Compliance Actions

August 11, 2021

Submitted by John Rowden, Interim General Manager

The most recent reported sample result from the Compliance point was taken on July 1, 2021 showed the arsenic levels at 13 ppb. The second quarter average was 9 ppb. The current Running Annual Average (RAA) is 10 ppb.

The July 1 reportable result from Well 1B was 8 ppb; The second Quarter 2021 average was 7 ppb, the RAA is 8 ppb.

The July 1 reportable result from Well 2 was 18; The second Quarter 2021 average was 16 ppb, the RAA is 15 ppb.

The results of the August test will be reported at the Board meeting if the information is available.

Iron and Manganese Compliance Levels

The most recent results of the tests of the Quarterly samples taken on July 1, 2021 for Iron were .380 mg/l at Well 1B and .220 mg/l at Well 2; for Manganese were .0576 mg/l at Well 1B and .080 mg/l at Well 2. (The Secondary Standard for Iron is .300 mg/l. The Secondary Standard for Manganese is .05 mg/l.).

Remediation Project Development

The District staff, met via Zoom, with the SWRCB Drinking Water Division staff. The state staff agreed to support the District in it's resubmittal of an application for an SRF construction loan. Farr West Engineering is addressing technical issues that were outstanding with the last application. Hauge Brueck Associates are expected to deliver the cultural and biological report on August 13.