

PLUMAS EUREKA COMMUNITY SERVICES DISTRICT
REGULAR BOARD MEETING August 10, 2022

Agenda Item #3 Resolution 2022-3 Repair of Lift Station 7 Notice of Exemption and Finding of Emergency

Background: Lift Station 7 is in urgent need of repair to the internal structure of the facility. The facility is in such disrepair that it is subject to immanent failure. The failure will result in raw sewage being directly spilled into the Middle Fork of the Feather River. The river is classified as Wild and Scenic according to . The river also flows into Lake Oroville, as source of drinking water. Problems with the lift station have been known, but the conditions have significantly deteriorated over the last three months due to the efforts to replace and repair failed pumps.

This agenda Item relates to a Board Resolution that makes the necessary findings and takes actions related to issuing a Notice of Exemption under CEQA and allow the District to hire a contractor without going through a lengthy bid process.

Recommendation: Pass Resolution 2022-3